



**LAMBRO INDUSTRIES, INC.**

Ventilation Accessories Since 1967

## **FOIL FLEX**

### **UL 2158A CLOTHES DRYER TRANSITION DUCT**

Check with local building codes prior to installation.

**Product:** UL 2158A Clothes Dryer Transition Duct

**Description:** Non-Insulated foil flexible duct reinforced with galvanized wire.

**Construction:** Multiple layers of aluminum / polyester laminate tape formed into a flexible duct bonded with premium heat cured fire retardant adhesive supported by a galvanized wire helix with a wire pitch of 1 inch.

**Components:**

- Aluminum / Polyester laminate
- Hot galvanized zinc coated bead wire - 0.0393 inch diameter
- UL approved fire-retardant water-based adhesive

**Specifications:**

- Wire pitch: 1 inch
- Duct Diameter: 4 inch

**Properties:**

Certified UL2158A - Conforms to all requirements of UL2158A for clothes dryer transition ducts.

- Operating temperature: -86°F to +257°F
- Maximum working pressure: +3000PA
- Resists tearing and puncturing

**NOTE:** Per UL 2158A, only ducts 8 foot lengths or less can be UL marked and installed.